


Standard Installation



| | | | |
|----------|---|-----------|--|
| 1 | Option A) 3/8" Comp x 1/2" FPT Connector (SKU: P-1035) | 10 | 3/8" Push Fit x 1/2" MPT (SKU: P-1044) |
| | Option B) 1/2" Comp x 1/2" FPT Connector (SKU: P-1021) | 11 | 3/8" OD LLDPE Polyethylene Tubing – Cut to size (SKU: T-1013) |
| 2 | 3/8" Push Fit x 1/2" MPT (SKU: P-1044) | 12 | 3/8" x 3/8" Push Fit Valve (SKU: P-1014) |
| 3 | 3/8" OD LLDPE Polyethylene Tubing – Cut to size (SKU: T-1013) | 13 | 3/8" OD LLDPE Polyethylene Tubing – Cut to size (SKU: T-1013) |
| 4 | 3/8" OD Push Fit Check Valve (SKU: P-1118) | 14 | 3/8" Stem x 3/8" Push Fit Elbow Connector (SKU: P-1106) |
| 5 | 3/8" OD LLDPE Polyethylene Tubing – Cut to size (SKU: T-1013) | 15 | EcoloxTech 240 Sanitizer System (SKU: E-240S) |
| 6 | 3/8" Push Fit x 1/2" MPT (SKU: P-1044) | 16 | 1/2" Stem x 1/2" Push Fit Elbow Connector (SKU: P-1105) |
| 7 | 3/4" MPT x 1/2" FPT Hex Bushing (SKU: P-1030) | 17 | 1/2" OD LLDPE Red Polyethylene Tubing – Cut to size (SKU: T-1063) |
| 8 | Filter Housing 3/4" FPT (SKU: F-1015) (SKU: F-1020) | 18 | 1/2" Push Fit x 1/2" MPT (SKU: P-1098) |
| 9 | 3/4" MPT x 1/2" FPT Hex Bushing (SKU: P-1030) | 19 | Flexible Hose with Mount (SKU: E-1100) |
| A | Mounting Screws – Quantity: 3 (SKU: P-1102) | C | EcoloxTech 240 Mounting Bracket (SKU: E-1071) Mounting Screws – Quantity: 4 (SKU: P-1103) |
| B | Mounting Kit for Filter Housing (SKU: E-3195) | D | Teflon Thread Seal Tape (SKU: P-1042) |

40 Gallon Holding Tank + Pump (SKU: E-4217)

Step 1: Connecting EcoloxTech 240 System Outflow to Holding Tank



| | | | |
|----------|---|----------|--|
| 1 | EcoloxTech 240 Sanitizer System (SKU: E-240S) | 4 | 3/4" MPT x 1/2" FPT Hex Bushing (SKU: P-1030) |
| 2 | 1/2" OD LLDPE Red Polyethylene Tubing (SKU: T-1063) | 5 | 40 Gallon Holding Tank with Pre-Installed Float Sensor (SKU: E-1190) |
| 3 | 1/2" Push Fit x 1/2" MPT (SKU: P-1098) | | |

Step 2: Connecting Holding Tank to Constant Pressure Pump



| | | | |
|----------|--|----------|---|
| 1 | 40 Gallon Holding Tank with Pre-Installed Float Sensor (SKU: E-1190) | 5 | 1" FPT X MPT PVC 90 Degree Elbow (SKU: P-4208) |
| 2 | 1" MPT x Socket PVC 90 Degree Elbow (SKU: P-1196) | 6 | Grundfos Scala2 Composite Pump - 110/120V (SKU: G-1011) |
| 3 | 1" PVC Schedule 40 Pipe – Cut to size (SKU: T-1200) | 7 | 1" FPT X MPT PVC 90 Degree Elbow (SKU: P-4208) |
| 4 | 1" Socket x FPT PVC Female Adapter (SKU: P-1198) | 8 | 1" Socket x FPT PVC Female Adapter (SKU: P-1198) |
| A | PVC Heavy-Duty Cement (SKU: C-4211) | | |

Step 3: Connecting Float Sensor to EcoloxTech 240 System



| | | | |
|----------|--|----------|---|
| 1 | 40 Gallon Holding Tank with Pre-Installed Float Sensor (SKU: E-1190) | 3 | EcoloxTech 240 Sanitizer System (SKU: E-240S) |
| 2 | Sensor-to-System Quick Connect Cable (SKU: E-3192) | | |

Operational Mode

After connecting the float switch sensor, the system must be set to “Level Mode”. See page 13 for instructions on changing the operational mode.

Remote Switch (SKU: E-1187)



| | | | |
|----------|--|----------|---|
| 1 | EcoloxTech 240 Sanitizer System (SKU: E-240S) | 3 | Remote Switch for Sanitizer Systems (SKU: E-1187) |
| 2 | Sensor-to-System Quick Connect Cable (SKU: E-3192) | | |

Operational Mode

After connecting the remote switch sensor, the system must be set to “Level Mode”. See page 13 for instructions on changing the operational mode.